

FRESHWATER SALINOMETER SL6000



Key features:

- Continuous check of salinity for freshwater generators and boilers
- Warning when the salinity surpasses a given value
- A built-in self test facilitates the routine check
- Direct reading of the salinity by LED bar
- 4-20 mA output
- Temperature compensation 20 - 90 c°
- Wall or panel mounting
- Type approval tested by DNV



Specifications, SL6000

Function:

The salinometer measures and supervises the salinity (salt content) of fresh water produced by distillation of sea water.

Mains supply:

90-120 or 200-240 Vac, 50-60 Hz

Mains current:

Mains supply must be secured against overcurrent with an external fuse.
Max. 100 mA

Salinometer power consumption:

Max. 10.0 W

Range of salinity:

0-20 ppm (0.1 ppm/step) of seasalt or
0-200 ppm (1 ppm/step) of seasalt.

Alarm level:

Adjustable 0-20 ppm (0-10 ppm 1 ppm/step)
(10-20 ppm 2 ppm/step)
or
Adjustable 10-200 ppm (10-100 ppm 10 ppm/step)
(100-200 ppm 20 ppm/step)

Test:

By means of a push button the salinometer circuit can be checked.

Cable connections:

Terminals 1-2:	Mains.
Terminals 3-10:	Relay contacts for ALARM and solenoides.
Terminals 11-14:	Electrode unit.
Terminal 15:	4-20 mA Currentloop.
Terminal 16:	Current ref, Ground.

Alarms to devices connected to the secondary relay can be cancelled by means of a push button "ALARM ON/OFF" on the front panel.

Display:

LED Bar.

Relay contacts:

8 A / 24 Vac
Relay contacts must be secured against overcurrent with an external fuse.

Protection:

IP 65


The gold-plated electrode unit is placed within the T-piece in such a way that it is easily removed for inspection and cleaning.






Electrode unit in standard T-piece





Electrode unit in flange T-piece



Wall mounting model



Panel mounting model



Amager Strandvej 124 · DK-2300 Copenhagen S
Tel: +45 3286 0525 · Fax: +45 3258 1330
mail: info@unielec.dk · www.unielec.dk

Visit us at www.unielec.dk

